

Desktop Review

Compliance Monitoring



Consent details			
Officer	Karli Green	Warrant #	5656
Address	1 Motutapu Island, Outlying Islands 1010		
Consent Number	WAT60274213	Date	08/10/2020
Consent Contact	Motutapu Outdoor Education Trust		

Update			
Works Started	Yes	Consent Status	Ongoing Monitoring
Consent Type	Water		

Rating Key:		Overall Rating
1 =	Fully Compliant	1
2 =	Evidence of minor effect(s) or potential for minor effect(s), including missing information. Enforcement action will be considered for on-going level 2 non-compliance	
3 =	Evidence of moderate effect(s) or potential for moderate effect(s). Enforcement action will be considered for level 3 non-compliance.	
4 =	Evidence of major effect(s). Enforcement action likely.	

General Comments
<p>Please continue to read the meter daily and upload the readings quarterly (or more regularly if you prefer).</p>

As a result of this review			
A followup review will be undertaken			
	Follow up	October	2021

Condition	Comments	Status
Condition 6 Authorised quantities	- Total daily abstraction not to exceed 25 cubic metres. - Total abstraction over the specified 12-month period (1 June to 31 May the following year) not to exceed 9,200 cubic metres.	1
Condition 7 Water meter installation	A water meter that's fit for purpose to be installed according to manufacturer's specifications and to Auckland Council's satisfaction.	1
Condition 8 Water meter maintenance	Water meter to be maintained and in working condition at all times.	1
Condition 9 Water meter recalibration / replacement	Water meter to be recalibrated or replaced every five years and evidence submitted to Auckland Council.	1
Condition 10 Water meter reading and reporting	- Water meter to be read daily and records kept. - Readings to be submitted to Auckland Council at the end of every February, May, August, and November.	1

[illegible]